


**NOTES:**

1. REDUCED PRESSURE PRINCIPLE ASSEMBLY.
2. EXPOSED PIPING TO BE INSULATED.
3. ALL FLANGED FITTINGS WHICH ARE BURIED SHALL HAVE PLASTIC WRAP, 30 MIL.
4. ALL THREE SIDES MUST BE LANDSCAPED AND SCREENED OR A "WEATHERGUARD BLANKET", OR "LOCKBOX", OR APPROVED EQUAL SHALL BE USED IN LIEU OF LANDSCAPING.
5. PAINT RUST-OLEUM #7771 SAND, HI-SOLIDS POLYURETHANE. SIZE OF DOUBLE DETECTOR CHECK SHALL MATCH FIRE SERVICE PIPING
6. PROVIDE  $\frac{3}{8}$ " CHAIN AND PADLOCKS FOR EACH GATE VALVE TO PREVENT UNAUTHORIZED OPERATION.

REVISIONS	DATE		<b>CITY OF TULARE</b> PUBLIC IMPROVEMENT STANDARD	
			<b>DOUBLE CHECK DETECTOR ASSEMBLY</b>	DRAWING NO.:  <b>6410</b>
			Approved By: <i>Michael W. Miller</i> Date: 11/15/16	City Engineer
			1 OF 1	