



TRACER WIRE SHALL BE BROUGHT TO THE SURFACE WITH A MINIMUM OF 18" ABOVE FINISH GRADE.

NOTES

1. MATERIALS AND CONSTRUCTION PROCEDURE SHALL BE IN ACCORDANCE WITH "TECHNICAL SPECIFICATIONS NO 16, WATER MAINS."
2. COLOR SHALL BE YELLOW, ENAMEL VALSPAR SUNSET GLOW 3009-02, OR APPROVED EQUAL.
3. HYDRANT BURY SHALL BE DUCTILE IRON.
4. TRENCH AND PAVEMENT RESTORATION SHALL BE PERFORMED IN ACCORDANCE WITH CITY OF TULARE, "TECHNICAL SPECIFICATIONS NO. 8, TRENCH AND PAVEMENT RESTORATION."

REVISIONS	DATE		CITY OF TULARE PUBLIC IMPROVEMENT STANDARD	
			FIRE HYDRANT	DRAWING NO.: 6315
			Approved By: <i>Michael W. Miller</i> Date: 11/15/16 City Engineer	1 OF 1