


PIPE SIZE	WORKING PRESSURE	TEST PRESSURE
4" - 8"	250 PSI	312 PSI
10" - 24"	200 PSI	300 PSI
26" - 30"	150 PSI	187 PSI

REVISIONS    	DATE    		<b>CITY OF TULARE</b> PUBLIC IMPROVEMENT STANDARD <b>WATERLINE TIE-IN</b>	DRAWING NO.:  <h2 style="text-align: center;">6335</h2>
			Approved By: <i>Michael W. Miller</i> Date: 11/15/16      City Engineer	1 OF 1