


NOTES:

1. STREETLIGHTS ON ARTERIAL STREETS WITH NO MEDIAN CURB SHALL BE 100 WATT – 9,500 LUMEN, LED LAMPS WITH CUT-OFF LUMINAIRES, LUMINAIRE ELEVATION OF 29', MOUNTED ON MARBLELITE POLES WITH 8' MAST ARMS AS PER SOUTHERN CALIFORNIA EDISON COMPANY STANDARDS. ALTERNATIVE STREETLIGHT POLES ARE SUBJECT TO APPROVAL BY THE CITY ENGINEER.
2. STREETLIGHTS SHALL BE INSTALLED AT LOCATIONS AS DETERMINED BY THE CITY ENGINEER UPON REVIEW OF SUBMITTED IMPROVEMENT PLANS.
3. TWO STREETLIGHTS SHALL BE INSTALLED AT EACH INTERSECTION. SHOULD THE DISTANCE BETWEEN INTERSECTIONS EXCEED 360', AN INTERMEDIATE STREETLIGHT, OR STREETLIGHTS, SHALL BE INSTALLED. SPACING OF STREETLIGHTS BETWEEN INTERSECTIONS WHERE REQUIRED SHALL BE 150' MINIMUM TO 220' MAXIMUM.
4. STREETLIGHTS SHALL BE INSTALLED ON BOTH SIDES OF THE STREET IN A STAGGERED PATTERN.
5. IF AN INTERSECTION IS SIGNALIZED, A STREETLIGHT SHALL BE INSTALLED ON EACH CORNER AS A PART OF THE TRAFFIC SIGNAL SYSTEM.
6. ALL STREETLIGHTS INSTALLED OR REPLACED IN THE CENTRAL BUSINESS DISTRICT ARE SUBJECT TO APPROVAL BY THE CITY ENGINEER.

REVISIONS	DATE
MAST ARM LENGTH, LUMINAIRE HT.	8/7/17



CITY OF TULARE
PUBLIC IMPROVEMENT STANDARD

ARTERIAL STREET LIGHTING, NO MEDIAN CURB

Michael W. Miller
Approved By: _____
Date: 08/07/17 City Engineer

DRAWING NO.:
7320

1 OF 1