


**SECTION A-A**

**NOTES:**

1. ALL CELLS IN CONC. BLOCKS SHALL BE FILLED SOLID WITH COURSE GROUT, MINIMUM 2000 PSI AT 28 DAYS.
2. CORNER BLOCK ENDS AND CENTER WEB SHALL BE CUT TO FORM CONCRETE BOND BEAM.
3. ALL HORIZONTAL AND VERTICAL JOINTS SHALL BE RAKED TO MATCH CENTER SCORED BLOCK.
4. CONC. BLOCK, MORTAR AND COARSE GROUT SHALL CONFORM WITH CBC, LATEST EDITION. BLOCKS SHALL BE 8"X8"X16" AND MINIMUM 2000 PSI.
5. REBAR SHALL BE GRADE 40 WITH A MINIMUM YIELD STRENGTH OF 40,000 PSI.
6. SLAB FLOOR & FOOTING SHALL BE CLASS 2 CONCRETE.
7. GROUND TO BE SLOPED 1% AWAY FROM WALLS.
8. LOCATION OF TRASH ENCLOSURE TO BE APPROVED BY THE SOLID WASTE DIVISION OF THE CITY OF TULARE.
9. THIS ENCLOSURE IS FOR STORAGE OF CITY OF TULARE SOLID WASTE CONTAINERS ONLY.
10. HINGES SHALL BE ATTACHED TO THE FRONT AND OUTSIDE OF ENCLOSURE WALL.
11. HUNG GATES SHALL SWING OPEN TO 180 DEGREES FROM THE CLOSED POSITION.
12. GATES SHALL BE METAL. GATE POST, GATE POST FOOTINGS, AND GATES SHALL BE DESIGNED BY OTHERS.
13. CANE BOLT WITH SLEEVES SHALL BE INSTALLED TO KEEP THE GATE IN THE OPEN AND CLOSED POSITIONS.
14. ENCLOSURE IS SUBJECT TO FINAL INSPECTION BY THE CITY OF TULARE SOLID WASTE DIVISION AND IS SUBJECT TO RECONSTRUCTION AT OWNER'S EXPENSE IF STANDARDS ARE NOT MET.

REVISIONS	DATE



**CITY OF TULARE**  
PUBLIC IMPROVEMENT STANDARD

**CAN ROLLOUT TRASH ENCLOSURE**

Approved By: *Michael W. Miller*

Date: 08/10/2020 City Engineer

DRAWING NO.:

**9017**

1 OF 1